

SAMPLE

DISINFECTANT RESIDUAL DATA QUARTERLY REPORT

PUBLIC WATER SYSTEM NAME: ABC Water Company

PUBLIC WATER SYSTEM ID: NV0011111

QUARTER (Circle One)	2009			
	ONE January, February, March	TWO April, May, June	THREE July, August, September	FOUR October, November, December

First Month of Quarter: Monthly Summary			
Month:	January		
Number of Samples Taken	3	AVERAGE of all disinfectant residuals for this month	0.9

Second Month of Quarter: Monthly Summary			
Month:	February		
Number of Samples Taken	3	AVERAGE of all disinfectant residuals for this month	0.85

Third Month of Quarter: Monthly Summary			
Month:	March		
Number of Samples Taken	3	AVERAGE of all disinfectant residuals for this month	0.8

Quarterly Summary			
Total Number of Samples Taken for this Quarter	9	AVERAGE of all disinfectant residuals for this quarter	0.85
HIGHEST Residual for this quarter	0.95		

Running Annual Average Summary ¹				
Quarter	A	B	C	D
Year-Quarter	2009-1	2008-2	2008-3	2008-4
Average for quarter	0.85	1.1	0.95	0.75
Running Annual Average (RAA)	$(A+B+C+D)/4 = (0.85+1.1+0.95+0.75)/4 = 0.91$			

1- Running annual average is the average of the last 12 months of monthly averages and will be computed after 12 months of data are available.

Signature: _____

Date: _____

Print Name: _____

Phone Number: _____

Mail To: Division of Environmental Protection
 Bureau of Safe Drinking Water
 901 South Stewart Street, Suite 4001
 Carson City, NV 89701

Form Due by the 10th of April, July, October, and January